

**GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE AND FIRE SERVICE DEPARTMENT**

From
Sri B. Nageswar Rao, M.Com., B.Ed.,
District Fire Officer
Guntur.

To
The Secretary & Correspondent,
NRI's INDIAN SPRINGS E.M. SCHOOL
Engineering & Technology,
Tenali, Guntur District.

Rc.No.518 /A2/2013, dated: 01-03-2013.

Sir,

Sub:- A.P. State Disaster Response and Fire Service Department – Southern Region –
Guntur District – Issuance of No Objection Certificate for Occupancy to the Existing
Educational Building of NRI's INDIAN SPRINGS E.M. SCHOOL, Tenali town,
Guntur District - Regarding.

- Ref:-
- 1) Section 13(2) of A.P. Fire Services Act, 1999 and Rule 15(2) of A.P. Fire and Emergency Operations and Levy of Fee Rule, 2006.
 - 2) Chief Office Memo. Rc.No. Instructions of 2305/B2/2007, dated:28-02-2007 and 12-09-2008.
 - 3) Lr. Rc.No. Nil, dated:08-02-2013 of the Correspondent NRI's INDIAN SPRINGS E.M. SCHOOL, Tenali town Guntur District
 - 4) G.O.Ms.No.154, Municipal Administration & Urban Development Department, Dated 13-03-2007 & Memo. No.4011/M1/2008, dt.19-05-2008.
 - 5)Provisional NOC Rc.No. 525 /2010 dt. 18-02-2010 of the District Fire Officer, Guntur.
 - 6)Endt.No: 518/A2/2013, dt: 13-02-2013 of the District Fire Officer, Guntur.
 - 7) Inspection Committee Report dt.27-02-2013.

Vide reference 3rd cited, the Correspondent, NRI's INDIAN SPRINGS E.M. SCHOOL, Tenali town Guntur District has reported that he has obtained provisional No Objection Certificate in the reference 5th cited, constructed Educational Building and requested to issue the No Objection Certificate for Occupancy in terms of G.O. reference 4th cited for the NRI's INDIAN SPRINGS E.M. SCHOOL, Tenali town Guntur District

2) Vide reference 7th cited, the inspection committee has inspected the building on 27-02-2013 and recommended for the issue of No Objection Certificate for occupancy for the above Educational Building.

3) Particulars of the Educational Building :-

- i) Height of the Building : 10.98 Meters
- ii) Open spaces :

Direction	Required as per NBC	Provided	Deficit /Remarks
North	06.00 Meters	39.51 meters	Open spaces exempted as per G. O .M.S .No: 154,dt. 13-03-2007 of M.A& U .Development Dept
East	06.00 Meters	174.16 meters	
South	06.00 Meters	14.00 meters	
West	06.00 Meters	06.00 meters	

iii Floor wise Particulars :- Ground floor + First floor

Sl. No.	Floor	Floor area in Sq. meters		Occupancy	No. of students & staff members in the floor
		Block-1	Block-2		
1	Ground floor	2533.54	1031.44	Educational	256
2	First floor	2533.54	--	Educational	300
3	Second floor	2533.54	--	Educational	300

The Management has remitted Fire Precaution Fee, penal charges and user charges at SBI, Piduguralla as mentioned hereunder.

Sl.No	Fees	User Charges	Penal Charges	Challan No. & date
1	2	3	4	5
1	1850			37079,dt.13-12-2012
2		8633		37078,dt.13-12-2012
3			41440	37080,dt.13-12-2012